

Service Killed

APPLICATION No.: 8278

TAP CLEARED 8627-1522

LOCATION: 18 Cleveland St.

OWNER: Morris P. Fox

MEASURES: 1/2" H lead Sept. 21, 1895

S from Cove (west) 346.6 ft.

W from E line Cleveland St. 9.1 ft.

S from N line house 12.2 ft.

7/1/86: Renewed from 1/2' outside curb stop to prop line

Stock: 10ft. 3/4" copper tubing 1 - 3/4" curb stop

1 - Caldwell stop box 2 - 3/4 x 5/8 lead to cop adapt. xs

=====

11/18/95 Shut off empty bldg

1/9/97 Checked Olejarz OFF

MUST CHANGE TO COPPER BEFORE TURNING ON

5-29-98 Renewed from main to inside cellar. (9.0 ft. ins. prop. line)

Stock: 41.0 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop, 1 - #1 Caldwell

Stop Box, 1 - 5/8" x 3/4" Fig. 413

5/29/98

FRI

9/6/2012 - CITY CREW KILLED SERVICE AT  
THE TAP

DATE

BEF.

AFT.

REMARKS

982204938

## METER HISTORY

## CHARGE OUTS

[illegible]