

8281

✓

12 Granfield

Fernando Dini

 $\frac{1}{2}''$

Coggeshall	157.7
Granfield	7.4
House	2.4

June 16, 1981 While pumping out service - broke wiper joint back of meter - Installed a 5/8" x 3/4" lead to copper adaptor XXS. Pumped service - OK now.

August 17, 1994

Arcadia Exc. renewed from the newly installed 8" ductile main on Grandfield St. to the property line Cont. supplied all stock & will maintain trench

28-ft 3/4" copper tubing 1-3/4" curb stop
1-Caldwell stop box 1-3/4x5/8 lead-cop adapt.xs
1-3/4" corporation tap Insp. M Rose III

Insp. M Rose III

[illegible]

CHARGE OUTS