

APPLICATION No.: 8387 $\frac{1}{2}$ " H lead

TAP CLEARED 8913-2364

LOCATION: 7 Beetle St.

OWNER: E.H. Santos

MEASURES: $\frac{1}{2}$ "

H lead

Oct. 21, 1895

W from

Belle. Ave.

77.0 ft.

S from N line

Beetle

9.8 ft.

W from E line

House

8.2 ft.

3/29/89: Renewed from main to a point 2 ft. in front of main
 Stock: 2ft. $\frac{3}{4}$ " copper tubing 1- $\frac{3}{4}$ x $\frac{5}{8}$ lead to cop adapt.xs
 1 - $\frac{1}{2}$ x $\frac{3}{4}$ Fig.413
 =====

*Leak in cellar checked by Hunt 1/32/91
 has pump in cellar*

1/24/91: Renewed from $\frac{1}{2}$ ' outside curb stop to ins.
 cellar (12ft. ins prop line Stock: 22ft. $\frac{3}{4}$ " copper
 tubing 1- $\frac{3}{4}$ " curb stop 1-Caldwell stop box
 1- $\frac{3}{4}$ x $\frac{5}{8}$ lead to cop adapt. xs.
 =====

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

3/29/89: TAP REAMED

9104-1570

[illegible]