

APPLICATION No.: 8396

TAP CLEARED

LOCATION: 358 Reed ST.

OWNER: Mildred Sylvia

MEASURES: 3/4"

11-1-1895

N from	Elm	71.4 ft.
W from E line	Reed	6.4 ft.
S from N line	House	11.5 ft.

8/16/79: Renewed 6" outside curbstop to the prop. line.
7½ ft. - 3/4" copper; 3/4" curb stop; Caldwell stop box;
2 - 3/4" x 3/4" lead-cop. adapt. XS;

6-22-01 Renewed from main to curb stop. Stock:
19ft. - 3/4" Copper tubing, 1 - Caldwell Stop Box,
1 - 5/8" x 3/4" Fig. 413

3/10/09 - City crew repaired water service damaged by NStar Gas
7 ft - 3/4" copper tubing; 2 - 3/4" curb stops. Gas Co to
maintain trench. Foreman: Danny Perry

9/23/08 west end water main rehab contract #4 perrina constr
renewed service from main to a point 4ft stock 4ft 1 copper tubing
1-1 corp tap 1-1x3/4 reducer insp T Ives cdm

DATE

BEF.

AFT.

REMARKS

7/22/01

2001-287-0321

6-22-01 Tap reamed

[illegible]

CHARGE OUTS

[illegible]