

APPLICATION No.: 8412

## TAP CLEARED

LOCATION: 119 Mill N.E. Cor. Summer

OWNER: Lilly Anderson

## MEASURES:

3/4"

E from

Summer

14.3 ft.

S from N line

Mill

6.4 ft.

E from W line

House

8.4 ft.

Oct. 19, 1964 Renewed from 1½ ft. outside curb stop to property line.

7½ ft. - 3/4" Copper tubing 3/4" cop to cop stop  
2# wiping solder

Oct. 21, 1974 Renewed from the new 8" main in Mill St. to 1 ft. outside line.

25 ft. - 3/4" Copper tubing 3/4" McDonald Tap  
3/4" McDonald curb stop 3/4" x 3/4" Cop to cop. cplg.  
Buffalo stop Box (1 ft. outside line)

Federico supplied all stock, labor, excavated & will maintain trench.

Measures of new 3/4" Curb Stop:

E x E line Summer St. 14.4 ft.

E x W line House 8.5 ft.

S x N line Mill St. 5.8 ft.

S x S line House 22.5 ft.

OWNER CALLED - 7-19-80 LEAK BEFORE METER - TOLD HIM  
TO GET PLUMBER - "HE SAID... LEAK WILL STOP"

7-27-89 SON CALLED LEAKING @ CLAMP NEAR SHUT OFF.  
AFRAID TO TURN HANDLE.

TEL. 9943450

DATE

BEF.

AFT.

REMARKS

7/11/52

Reamed

[illegible]

## CHARGE OUTS

[illegible]