

APPLICATION No.: 8477 10"

TAP CLEARED

LOCATION: 57-63  
53 Cove St.

OWNER: Naushon Mill

MEASURES: 10"

## FIRE SUPPLY

S from	Gifford (E)	2.0 ft.
W from E line	Harbor	3.8 ft.
N from N line	Main Mill	14.4 ft.

DATE

BEF.

AFT.

REMARKS

## METER HISTORY

[illegible]

## CHARGE OUTS



APPLICATION No.: 8477

TAP CLEARED



LOCATION: 30 Harbor

OWNER: COR. GIFFORD ST. FIRE SUPPLY

MEASURES: 10"

S from	Gifford	2.0 ft.
W from E line	Harbor	3.8 ft.
N from N line	main mill	14.4 ft.

June 4, 2002 Repaired split on 10" CI fire supply by installing a 4 ft. pc.  
of 10" ductile pipe & 2 0 SB #441 Cast cplgs.

Measures of cplgs.:

E x W line Harbor St. 23.0 ft.

E x W line Harbor St. 27.0 ft.

[illegible]



## SERVICE

Application No.

8477

St. &amp; No.

30

Harbor

Size Pipe

10"

Kind Pipe

Cast iron

Laid

Mar. 9, 1896

S

from

Gifford (east)

St.

2.0 ft

7

from

E

line

Harbor

St.

3.8 ft

N

from

N

line

main Mill

St.

14.4 ft

Private stop gate

(over)

City

ft. Earth

Taker

ft. Earth

ft. Pipe

ft. Pipe

261 80

Also supplies 9693 conn. (49 Cove)

July 12, 1915 changed sprinkler connections  
No. 2 weave shed from west to east side to connect with yard main Appli. 8477 from Harbor St., using,

418 ft. 6" C.I. pipe

24 ft. 8" C.I. "

See bill 10384.

SERVICE

SERVICE

Application No. 9693 C

St. &amp; No.

49

Cove

FROM HARBOR ST.

Size Pipe

3/4"

Kind Pipe

H lead

Laid

Dec. 18, 1899

Stop box

N

from

N line

Machine shop

St. 4.4 ft.

W

from

E line

"

"

St. 1.6 ft.

from

line Conn. of #8477

St. ft.

For Machine shop &amp; cloth rm. (over)

City

ft. Earth

Taker

ft. Earth

ft. Pipe

94

ft. Pipe

45 28

Library Bureau 017419

Taps 4 inch. pipe in yard supply to #1  
Boiler Room

3 ft. E from E line Boiler Room ✓

32.5 ft. N from S line Boiler Room.