

APPLICATION No.: 8498

TAP CLEARED

LOCATION: 104 Mosher St.

OWNER: John Almeida

MEASURES: $\frac{1}{2}$ " H lead Apr. 21, 1896

E from Crapo St. 19.7 ft.

N from S line Mosher St. 9.1 ft.

W from E line house 9.1 ft.

April 5, 1973 Renewed from the main to curb stop.
 9 ft. - $\frac{3}{4}$ " Copper tubing $\frac{3}{4}$ " Hays curb stop
 4" x $\frac{3}{4}$ " Dresser style 91
 Service Saddle

- - -

March 25, 1968 Renewed from $\frac{1}{2}$ ft. outside curb stop to
 inside of cellar.
 23 $\frac{1}{2}$ ft. - $\frac{3}{4}$ " Copper tubing (13 ft. inside)
 $\frac{3}{4}$ " Curb Stop 1 wipe joint

- - -

3/18/88 renewed from main to a point $1\frac{1}{2}$ ft: Tapped off new 6" main by
 Spinello Const. stock by Contractor
 $1\frac{1}{2}$ ft- $\frac{3}{4}$ " copper tubing 1- $\frac{3}{4}$ x $\frac{3}{4}$ cop to cop cplg comp
 1- $\frac{3}{4}$ " corporation tap Insp M Rose

meter couplings leaking tightened Bento 8/14/90

[illegible]

CHARGE OUTS

[illegible]