

## TAP CLEARED

LOCATION: 179 Belleville Ave.

OWNER: Filomena Soares

MEASURES: 5/8"

H lead

Apr. 28, 1896

S' from

Beetle

~~46.0 ft~~ 46.0 ft.

E from W line

Belleville Ave. ~~2904~~

9.6 ft

N from N line

House

17.9 ft	18.6 ft
---------	---------

E x E line

House

12.0 ft.

House	12.0	ft.
-------	------	-----

a point

meter inside cellar to a point

June 6, 1957 Renewed from meter inside cellar to a point  
8 ft. from meter.

8 ft. - 3/4" copper tubing.

7/7/76: Due to the installation of the 48" main this service has been renewed from the main to 11 ft. from the main. Stock supplied & inst. by Zoppo. 1" Corporation Ford compression; 1" x 3/4" Reducer; 11 ft. 3/4" copper tubing; 3/4" curb stop Ford compression; 3/4" x 5/8" lead to copper adaptor XXS; Measures of 1" Corporation: S x S line Beetle St. 44.6 ft. E x W line Belleville Ave. 18.0 ft.

8/4/87: all copper inside of property is 1/2" and they probably complain about poor pressure for 3 tenement houses.

$$\begin{array}{r} 18 \\ -11 \\ \hline 7 \text{ Fl.} \end{array}$$



## METER HISTORY

## CHARGE OUTS

[illegible]



APPLICATION No.: 13625 C 5/8" Lead

TAP CLEARED

LOCATION: 179 $\frac{1}{2}$  Belleville Ave.

OWNER:

MEASURES: 5/8" lead Oct. 1, 1910  
Connection of Appli. #8532, made by owner.

DATE

BEF.

AFT.

REMARKS



## METER HISTORY

## CHARGE OUTS

[illegible]

CHARGE OUTS