

APPLICATION No.: 8533

TAP CLEARED ✓

LOCATION: 75 DURFEE ST

OWNER: DAVIS COATES

31-313

MEASURES:

3/4" L. LEAD

E from BULLOCK ST 80.9  
S from N line DURFEE ST 5.7  
W from E line HOUSE 2.8

Oct. 2, 1995: Renewed from main to a point 10 inches  
Stock: 10 inches 3/4" copper tubing 1-3/4x3/4 cop-cop cplg.comp  
1- 3/4x3/4 Fig 413

April 3, 1974 Relocated service from 8" main to new 12" main.  
Renewed from main to 1 ft. inside curb stop. STOCK: 18' 3/4" copper  
tubing; 3/4" corp.; 3/4" Curb Stop; Stop Box.

5/26/05 Renewed from Curb Stop to inside cellar.  
STOCK: 18 ft. 3/4" Copper Tubing; Caldwell Stop Box.

DATE BEF. AFT. REMARKS

10/2/95 954000269

10/2/95: tap reamed

[illegible]

## CHARGE OUTS