

APPLICATION No.: 8572 $\frac{1}{2}$ "

TAP CLEARED

LOCATION: 32 Cove St.

OWNER: J.V. & Maria Medeiros

MEASURES: $\frac{1}{2}$ "

W from Roosevelt 64.5 ft.

N from S line Cove 8.4 ft.

W from E line House 6.2 ft.

12/29/77: Renewed 6" outside curb stop to prop. line.
9 ft. - $\frac{3}{4}$ " copper; 2- $\frac{5}{8}$ " x $\frac{3}{4}$ " lead to cop. adapt.XS;
 $\frac{3}{4}$ " curb stop; Caldwell stop box;

10/21/10 - City crew renewed from main to curb stop

12 ft. - $\frac{3}{4}$ " copper tubing; 1 Caldwell stop box;
1 - $\frac{5}{8}$ " x $\frac{3}{4}$ " Fig 413; Tap reamed

Foreman: Dana Farland -----

DATE

BEF.

AFT.

REMARKS

10/21/10 8:00
10-21-102010-4307249
TAP REAMED

INACTIVE SER

SEE BACK CARD

FOR SER NUMBER

[illegible]

CHARGE OUTS

[illegible]

APPLICATION No.: 18787 C 5/8" H lead

TAP CLEARED

LOCATION: Cove St. S.S. W. of Roosevelt St.

OWNER:

MEASURES: 5/8" Ser. H lead
Conn. of App. 8572 made by city

DATE

BEF.

AFT.

REMARKS

10/21/10 8:00
10-21-10

2010-4307249

Tap reamed

12/29/77 - Renewed 6" outside curb stop to prop. line
on Acct # 8572
9 ft -3/4" copper tubing; 2 -5/8" x 3/4" lead to cop
adapt xs, 3/4" curb stop; 1 Caldwell stop box

10/21/10 - City crew renewed from main to curb stop
on Acct# 8572
12 ft -3/4" copper tubing; 1 Caldwell stop box;
1 -5/8" x 3/4" Fig 413; Tap reamed. Foreman: D. Farland

[illegible]

CHARGE OUTS

[illegible]