APPLICATION No.: 8597 3/4"	TAP CLEARED 8503- 000			
LOCATION: 243 Chestnut St.	DATE	BEF.	AFT.	REMARKS
OWNER: Luella F.R. Rússell	5/10/61			reamed
MEASURES: 3/4"	4/2/85	TAP	REAM	ED
S from Merrimae 62.2 ft.				
E from W line Chestnut 7.0 ft.				
N from S line House 4.3 ft.				
May 10. 1961 Rewiped joint at tap lab wiping solder	1			
Jan 14.1985: Renewed from 1/2' outside curb stop to a point 5.0 ft.				
Stock: 5.5 ft. 3/4" copper tubing 1 3/4" curb stop old stop box used 23/4 x 5/8 lead to cop. adapt. xxs				
this service has very very poor pressure.				
4/2/85: REnewed from main to a point 1.0ft.				
Stock: 1.0ft. 3/4" copper tubing 1 3/4x5/8 lead				
to cop adapt. comp. xxs 3/4x1" Fig.413				
11/7/06 Renewed from 1/2 ft. outside curb stop to inside	de			
cellar. (8 ft. inside property line) Stock: 10 ft. 3/4				
copper tubing; caldwell stop box; 3/4" x 3/4" cop=cop cplg., comp				
11/29/06 Caliacco Corp. renewed from the main to the property				
line 12.5 ft. of 3/4" copper tubing.				

