

APPLICATION No.: 8617

TAP CLEARED



LOCATION: 2 GREENE ST

OWNER: HYMAN HORVITZ

31-313

MEASURES: 5/8" H lead June 3, 1896

N from ALLEN ST 117.0 ft

W from E line GREENE ST 7.0 ft

N from S line HOUSE 11.1 ft

Sept 14, 1994:

Biszko Cont. renewed from newly installed 8" ductile main on
Greene St. to prop line Cont. supplied all stock
25 ft 3/4" copper tubing 1-3/4" curb stop
1- Caldwell stop box 1-3/4x5/8 lead-cop adapt.xxs
1- 3/4" corporation tap Insp. F Bento

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]

APPLICATION No.: 8617

TAP CLEARED ^{8/10} 87330106

LOCATION: 2 Greene St.

OWNER: Hyman Horvitz

DATE BEF. AFT. REMARKS

8/10/87: TAP REAMED

MEASURES: 5/8" H lead June 3, 1896

N from Allen St. 117.0 ft.

W from E line Greene St. 7.0 ft.

N from S line house 11.1 ft.

8/10/87: Renewed from main to a point 1.0 ft.

Stock: 1.0 ft. 3/4" copper tubing 1-3/4x5/8 lead to
cop adapt. xxs 1-3/4x5/8 Fig. 4133-14-88 Renewed from 1' outside curb stop to a point 2ft
3ft-3/4" copper tubing, 1-3/4" curb stop, 1-Caldwell stop box
2-5/8x3/4 lead to cop adapt xxs

Took color sample 12/16/88

Made report for mayor's office 12/19/88

9/17/83: meter shutoff leaking--checked by Breton--owner Ildelutra
SousaTook color sample J. R. 3/16/90 Crystal clear
4/19/90 sample clear

Flush service 7/11/90 Silver + Hansen

[illegible]

CHARGE OUTS

[illegible]