

SERVICE

Application No. 8621

St. & No. 1262-4 Acushnet Ave.

Size Pipe Kind Pipe

Laid

5/8"

H lead

June 11, 1896

N from Holly (east) St. 14.2 ft.

W from E line Acush. Ave. St. 7.4 ft.

S from N line store St. 4.5 ft.

Removed 3/25/87

City

36 ft. Earth

Taker

2 ft. Earth

35 ft. Pipe

3 1/2 ft. Pipe

3.06

2-18-57, ser. leak, renewed from tap to a point 2 ft. from tap using 2 ft. $3/4$ " cop. tubing type K. soft., 1- $3/4$ " cop. cplg. Fig. 413, 1 lb. wiping solder, tap reamed.

2/20/70, renewed from 6" outside curb stop to a point $3\frac{1}{2}$ ft.; 4 ft. $3/4$ " copper tubing; 1- $3/4$ " Hays curb stop; 1 Buffalo-stop box.

9/2/76 Renewed from $3\frac{1}{2}$ ft. inside curbstop to inside cellar. 10 ft. $3/4$ " copper (4 ft. ins.); $3/4$ " compression cplg. ($3\frac{1}{2}$ ft. inside curbstop)

3/25/87-Shut off & removed at tap. All material left in ground.