

APPLICATION No.: 8636

TAP CLEARED

LOCATION: N.S. Market St. E x Sixth St.

OWNER: N.B. Public Library

MEASURES: 3/4" Copper April 15, 1980

E from E line Sixth St. 32.0 ft.

S from N line Market St.	11.6 ft.
--------------------------	----------

4/15/80 Renewed this service from the main to a point
7 ft. inside property line (to a hose connection
for lawn sprinkler)

45.5 ft. - 3/4" Copper tubing

1 - 3/4" Curb Stop

1 - 3/4" Curb Stop with waste

2 Caldwell Stop Boxes

1 - 3/4" sweat fitting - for hose connection & cap

Main to curb stop 26.5 ft.

curb stop to waste

stop ins. prop. 14 ft.

waste stop to hose

conn. 5 ft.

INACTIVE

[illegible]

CHARGE OUTS

[illegible]

APPLICATION No.: 8636

TAP CLEARED

LOCATION: N.S. Market St. E x Sixth

OWNER: Library

MEASURES: 5/8"

Lead

June 29, 1896

Stop Box in Library Lawn

N x S line Library Curbing

2.2 ft.

E x W line Library Curbing

34.3 ft.

E x W line Library Building

26.3 ft.

July 25, 1974 Repaired leak at meter pit. Relocated
curb stop to 6.0 ft. S x meter pit in sidewalk.
8 1/2 ft. - 3/4" Copper tubing 3/4" curb stop
Caldwell Stop Box 1 wipe joint
3/4" cop. cplg.

4/26/1911 This service extended to new location of lawn
hydt. and new lawn hydt. set.

4/7/1966 Renewed from meter to 7 ft. outside meter.
7 ft. - 3/4" Copper tubing 3/4" curb stop

6/7/1966 Leaking by stop, replaced with reused curb stop.

5/3/67 Leak inside pit -
1 ft. - 3/4" Copper tubing inside curb stop
3/4" x 3/4" copper adaptor

9/6/78: Leak at curb stop & relocated curb stop. 6 ft. - 3/4" copper; 3/4" x 3/4" cop. -
cop. comp. cplg; Caldwell stop box; 3/4" curb stop; 5/8" x 3/4" lead to cop. adapt. XS

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]

APPLICATION No.: 8636

TAP CLEARED

LOCATION: 601 Pleasant Cor. Market

OWNER:

MEASURES:

5/8" 3/4 COPPER

Stop-box in Library lawn

N from S line Library curbing 2.2 ft.

E from W line " " 34.3 ft.

E from W line " Bldg. 26.3 ft.

August 15, 1973 Repaired leak in meter pit.

1 ft. - 3/4" Copper tubing 1 wipe joint

- - -

INACTIVE
SERVICE

DATE

BEF.

AFT.

REMARKS

WHEN SHUTTING OFF OR TURNING ON USE STOP & WASTE INSIDE
GRASS OR BOX INSTEAD OF CURB STOP.

[illegible]

CHARGE OUTS