

DUPLICATE CARD Lost original  
TAP CLEARED

APPLICATION No.: 8659

LOCATION: 148 Rotch St. E.S. S of Court St.

OWNER:

MEASURES: 5/8" L. lead Aug. 1, 1896

S x Court St. 93.4 ft.  
W x E line Rotch St. 8.2 ft.  
S x N line house 2.6 ft.

Feb 11, 1997:

Renewed from 1/2' outside curb stop to a point 3.5 ft  
Stock: 4.0 ft 3/4" copper tubing 1-3/4" curb stop  
1- Caldwell stop box 2- 3/4x5/8 lead-cop adapt.xxs  
=====

June 26, 1997:

Renewed from main to ins.cellar ( 12ft ins.prop line)  
Stock: 40ft 3/4" copper tubing 1-3/4" curb stop  
1-caldwell stop box 1-3/4x5/8 Fig 413  
=====

6-16-98 Biszko Cont renewed service from the newly installed 8"  
ductile main to a point 2 ft from the main. Stock supplied by  
Contractor: 2 ft. - 3/4" Copper tubing, 1 - 3/4" x 3/4" cop to cop  
cplg., comp. Contractor to maintain cut.

Nov. 22, 1999 Checked by Meter Room - for poor pressure - problem inside second floor faucet

DATE BEF. AFT. REMARKS

972606532

6/26/97: tap reamed

[illegible]

## CHARGE OUTS

[illegible]