

8780

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

OWNER:

9/7/88

tap reamed

31-313

MEASURES: 5/8"

E	Howard S t.	69.3 ft.
---	-------------	----------

S x N line	Coggeshall St.	10.2 ft.
------------	----------------	----------

E x W line	eggshell	15.9 ft.
------------	----------	----------

12/4/63: ser. leak, renewed from 6" outside curb stop to 4-1/2' inside curb stop, using 5 ft. 3/4" copper tubing, 1-3/4" copstop Fig. 415, 2# wiping solder, 125 compressor: 1/2 hour.

9/7/88: renewed from main to a point 2 ft. 2' - 3/4" copper tubing  
3/4x5/8 lead to cop adapt, xxs, 3/4x5/8 Fig. 413, tap reamed

\_\_\_\_\_

[illegible]

## CHARGE OUTS

[illegible]