

APPLICATION No.: 8916

TAP CLEARED ✓

LOCATION: 109 Purchase St.OWNER: Joseph R. Martins

MEASURES:

 $\frac{1}{2}$ "

H lead

Dec. 21, 1896

S from

Thompson St.

62.9 ft.

E from W line

Purchase St.

6.2 ft.

S from N line

house

7.3 ft.

12/14/92: Renewed from $\frac{1}{2}$ ' outside curb stop to ins cellar6ft ins. prop line Stock: 16ft $\frac{3}{4}$ " copper tubing1- $\frac{3}{4}$ " curb stop 1-Caldwell stop box 1- $\frac{3}{4}$ x $\frac{5}{8}$ lead-cop adapt.xs

=====

3/30/93: Renewed from main to curb stop Stock: 9ft $\frac{3}{4}$ "copper tubing 1- $\frac{3}{4}$ x $\frac{5}{8}$ Fig 413 NOTE: CHANGED LEAD TO COPPER

WHILE CONTRACTOR HAD TRENCH OPEN

=====

DATE

BEF.

AFT.

REMARKS

12-14-

92

9251 0038

3/30/93: TAP REAMED

[illegible]

CHARGE OUTS
