

APPLICATION No.: 8917

TAP CLEARED 8529-0015

LOCATION: 13 Cleveland St.

OWNER: Albert E. Puckles

MEASURES: 5/8" H lead Jan. 8, 1896

S from Cove St. 278.5 ft.

E from W line Cleveland St. 8.5 ft.

N from S line house 7.8 ft.

Ju ly 11, 1944 New 5/8" H. Leak pipe 16' E X Building to inside
basement wall.

17 ft. - 5/8" H. lead pipe pumping plumber's bill

Feb. 18, 1944 Leak about 10 ft. from front of house in yard.

6' - 5/8" H. lead pipe

Oct. 25, 1961 Rewiped joint at tap.

Tap reamed 1 lb. wiping solder

1 street cut 5' X 2' Warrenite Comp. Jaeger 1 hr.

Abraham Alfonso

7/15/85: Renewed from 1/2' outside curb stop to a point 5 ft. inside

Stock: 5 1/2 ft. 3/4" copper tubing 2 3/4x5/8 lead to cop adapt.

xs 1 3/4" curb stop 1 Caldwell stop box

=====

=====

DATE

BEF.

AFT.

REMARKS

METER HISTORY

CHARGE OUTS

[illegible]