APPLICATION No.:8976	TAP CLEARED			
LOCATION: 224 - 226 Grinnell St	DATE	BEF.	AFT.	REMARKS
OWNER:				
MEASURES: March 22, 1897 E X Dartmouth St N X S Line Grinnell St E X W Line House 7.1 ft 1" Copper Service 04/02/2019 Lead Service Line Replacement Program Phase 1, Contractor P Gioioso & SON Type CU, Diameter 1in, Water pressure 80 Distance curb stop to main (ft) 7 Distance curb stop to meter (ft) 25.9 Distance curb face to curb stop (ft) 1.0 Depth of service (ft) 4.3 Total length ofnew pipe installed (ft) 25.9 Curb stop replaced: No size 3/4" Corporation replaced: No size 3/4" Ball Valve Furnished: Yes size 1" Remarks: 1-3/4" union installed 11f outside curb stop				

