

APPLICATION No.: 9087

TAP CLEARED

8743-1379

LOCATION: 12 Scott

OWNER: Victorea Saulnier

DATE

BEF.

AFT.

REMARKS

10-21-87

reamed

MEASURES: 3/4" + 5/8 LEAD

| | | |
|---------------|--------|-----------|
| W from | County | 129.8 ft. |
| N from S line | Scott | 9.1 ft. |
| W from E line | House | 4.2 ft. |

10-21-87 Renewed from main to a point 7ft inside curb stop
16ft-3/4" copper tubing, 1-3/4" curb stop, 1-Caldwell stop box
1-5/8x3/4 lead to cop adapt s-x, 1-5/8x3/4 Fig 413

1" Copper Service

07/09/2019 Lead Service Replacement Prgoram
Phase 1, Contractor P Gioioso & Son
Type CU, Diameter 1in, Water pressure 100
Distance from main to curb stop (ft) N/A
Distance from curb stop to meter (ft) 19
Distance from curb face to curb stop (ft) 2
Depth of service (ft) 4.5
Total length of new pipe installed (ft) 19
Curb stop replaced: Yes size 1"
Corporation replaced: No
Ball valve replaced: Yes size 1"

METER HISTORY

| DATE | SET OUT | SIZE | MAKE | NUMBER | READING | TEST | | | REMARKS |
|--------|------------|------|--------------|----------|---------|------|--|--|---------|
| | | | | | | | | | |
| 8-1-66 | | 3/4 | Rockwell Mar | 19384423 | | | | | |
| | | | | | | | | | |

CHARGE OUTS

