

APPLICATION No.: 9143

TAP CLEARED

8331-0476

LOCATION: 125 Rockland

OWNER: Joseph Arruda

DATE

BEF.

AFT.

REMARKS

6/28/76

Reamed

MEASURES:

3/4"

E from

Orchard

57.1 ft.

S from N line

Rockland

7.0 ft.

E from W line

House

7.1 ft.

 June 5, 1962 Renewed from $\frac{1}{2}$ ft. outside the curb stop to meter
 inside the building.

14 $\frac{1}{2}$ ft. of 3/4" copper tubing 1 3/4" cop. to cop. stop
 1 lb. wiping solder

June 28, 1976 Renewed from the main to 2 ft. in front of
 the main.

2 ft. - 3/4" Copper tubing 3/4" x 3/4" Fig. 413
 5/8" x 3/4" lead to copper adaptor XXS

Aug. 8, 1983 Renewed from main to a point 3 $\frac{1}{2}$ ' from main.

1-3/4" Corporation tap 1-8" Repair Saddle Smith & Blair

3.5-3/4" copper tubing 1-3/4" x 5/8" lead-cop. adapt. XXS

Aug. 23, 1983 Renewed from main to curb stop.

20 ft. - 3/4" copper tubing Same stop box

[illegible]