

APPLICATION No.: 9153

## TAP CLEARED

LOCATION: 187 Davis St.

OWNER: Donald L. Desautels

MEASURES:

5/8"

E from	Acush. Ave.	288.4
S from N line	Davis	8.5
E from E line	House	1.7

July 9, 1962 Renewed from main to  $3\frac{1}{2}$  ft. from main  
 $3\frac{1}{2}$  ft. of  $3/4$ " copper tubing 5/8" reused corp. cplg.  
 1b. wiping solder

11/27/78: Franklin Const. renewed service from the main  
 to the property line. 32 ft.  $3/4$ " copper; 5/8" x  $3/4$ "  
 Fig. 413;  $3/4$ " curb stop; Caldwell stop box; 5/8" x  $3/4$ "  
 lead-cop. adapt. XXS;

6/22/06 Replaced Top section of curb stop box buried  
 in cement - plumber needed water shut-off for repairs  
 inside the house. Stock: 1 Caldwell stop box Top sect  
 Foreman: Bento  
 -----

DATE

BEF.

AFT.

REMARKS

7/9/62

REPAIRED

[illegible]

## CHARGE OUTS