

APPLICATION No.: 9160-

TAP CLEARED

LOCATION: 1182 Acushnet Ave.

OWNER: Kaplan Bros.

MEASURES:

3/4"

Nov. 7, 1968

Nov. 6, 7, 8, 1968 Renewed from the main to the meter ins the cellar.

The defective 5/8" Corp. was replaced with a 1" Corporation 1" x 3/4" reducing cplg. was installed 1 ft. from the main.

42 ft. - 3/4" Copper tubing (4 ft. inside)

1" Hays corporation

3/4" Mueller curb stop

1" x 3/4" reducing cplg.

5/5/05 Jw LAKE IN. REMOVED 2 S45 & ADDED

TO D.W.W LIST.... BEN TO

INACTIVE SER

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]

APPLICATION No.: 9160

5/8

TAP CLEARED

LOCATION: 1180-88 Acushnet Ave.

OWNER: Kaplan Bros. Furniture Co., Inc.

MEASURES: 5/8"

H lead

June 23, 1897

S from

Sawyer St.

58.1 ft.

W from E line

Acush. Ave.

6.3 ft.

S from N line

bldg.

25.3 ft.

DATE

BEF.

AFT.

REMARKS

9/26/78

3/4 x 3/4 x 3/4

Tee in front
Curb stop
for
Cement lining

[illegible]
