

APPLICATION No.: 9180

TAP CLEARED 8943-3813

LOCATION: 385 Reed

OWNER: Lavine M Chase

DATE

BEF.

AFT.

REMARKS

10/26/89: TAP REAMED

MEASURES: 3/4"

7-14-1897

S from Kempton W 172.0 ft.

E from W line Reed 6.1 ft.

S from N line House 3.7 ft.

February 1, 1960 Renewed from $\frac{1}{2}$ ft. outside curb stop to 2 ft. inside
the curb stop.

$2\frac{1}{2}$ ft. of 3/4" copper tubing 2 lbs. wiping solder

10/26/89: Renewed from main to a point 1 ft.

Stock: 1 ft. 3/4" copper tubing 1-3/4x5/8 lead to cop adapt. xxs

1 - 3/4 x 3/4 Fig.413 =====

9/22/08v west end water main rehab contract #4 perrina constr
renewed service from main to prop line stock 12.5ft 1 copper tubing
1-1 corp tap 1-1 curb stop 1-1 3/4 reducer insp T Ives cdm

3/27/17: Service renewed from curb stop in by Contractor

WC SMITH, Inspected by P. Reynolds

[illegible]

CHARGE OUTS

[illegible]