

APPLICATION No.: 9204

TAP CLEARED

LOCATION: 159 Bonney St

OWNER:

31-313

MEASURES:

July 24, 1897

S from Rockland St 164.0'

E from W line Bonney St 8.0'

S from N line house 12.2'

1"COPPER SERVICE

10-17-2018: Lead service line replacement program

phase1: TYPE: CU, Diameter 1", Water Pressure 80

Distance from main to curb stop 9'

Distance curb stop to meter 24'

Distance from curb face to curb stop 1.5'

Depth of service 4.0'

Total length of new pipe installed 24'

Curb stop replaced: NO Size 3/4"

Corporation replaced: NO Size 3/4"

Ball Valve furnished: YES Size 1"

remarks- 1-3/4" union installed 1LF outside curbstop

Contractor: P. Gioioso & S

DATE

BEF.

AFT.

REMARKS

02-02-94

09-21-94

tap needed

[illegible]

CHARGE OUTS

