

APPLICATION No.: 9214

TAP CLEARED

LOCATION: 88 Mosher St.

OWNER: Antoni Benbenek

MEASURES:  $\frac{1}{8}$ " H lead July 31, 1892

E from Crapo St. 155.8 ft.

N from S line Mosher St. 9.0 ft.

E from E line house 5.0 ft.

9/28/83 checked by Ostiguy for poor pressure complaint.  
Pressure at faucet in cellar - very good pressure.  
Owner dug up behind meter - Ostiguy claims that he has  
1/2" galvanized - possible cause of poor pressure on  
2 other floors. Told him renewal would cost 300. - does  
not want it renewed cannot afford it.

3/23/88 Renewed from main to a point 1 ft: Tapped off new 6" main by  
Spinello const. Stock by contractors  
1ft-3/4" copper tubing 1-5/8x3/4 lead to cop adapt xs  
1-3/4" corporation tap Insp M Rose

7-21-99 Renewed from main to property line. Stock:  
16 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop,  
1 - Caldwell Stop Box, 1 - 3/4" x 3/4" cop to cop.,  
comp.

[illegible]

## CHARGE OUTS

[illegible]