

APPLICATION No.: 9222

TAP CLEARED

LOCATION: 343 Orchard St

OWNER:

31-313

MEASURES: Aug 10, 1897

S X Washington St

251.0 ft

E X W Line Orchard St

7.0 ft

S X N Line House

4.4 ft

1" Copper Service

10/10/2018 Lead Service Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 90

Distance from main to curb stop (Ft) 7

Distance from curb stop to meter (ft) 25.8

Distance from curb face to curb stop (ft) 0.8

Depth of service (ft) 4.5

Total length of new pipe installed (Ft) 25.8

Curb stop replaced: No size 3/4"

Corporation replaced: no size 3/4"

Ball valve replaced: Yes size 1"

Remarks: 3/4-1 union installed 1.0 LF outside curb stop

DATE

BEF.

AFT.

REMARKS

7/8/74 Ream

6/6/06 Ream

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

CHARGE OUTS

