

9231



50 Larch St.

Frank R. Figueira

E from W line house 11.0 ft.

2 - 5/8" x 3/4" lead to copper adaptor XXS

7/29/10 - City crew renewed service from main to
property line - due to tap leak
18 ft - 3/4" copper tubing; 1 -3/4" curb stop;
1 Caldwell stop box; 1 -5/8" x 3/4" lead to cop adapt;
1 -5/8" x 3/4" Fig. 413; Tap reamed
Foreman: Frank Bento

BRADBURY-WARING, INC.

[illegible]

CHARGE OUTS

[illegible]