

LOCATION: 4 Clinton Place

OWNER: Martha Groh

MEASURES: 3/4"

S from	Clinton	88.6 ft.
W from W line	House	19.7 ft.
N from S line	House	11.7 ft.

✓ Sept. 18, 1969 Renewed from 6" outside curb stop to 6 1/2" inside curb.

1 - 3/4" Hays curb stop

2 - wipe joints

✓ 12/6/78: Renewed 6" outside curbstop to 4 1/2 ft. inside; 5 ft. - 3/4" copper; 3/4" curbstop; 2-5/8" x 3/4" lead-copper adapt. XXS; Caldwell stop box;

✓ 12/11/78: Renewed from main to 1 ft. front of main. 1 ft. - 3/4" copper; 5/8" x 3/4" lead-cop. adapt. XXS; 3/4" x 3/4" Fig. 413;

✓ 7/14/86: renewed from 1/2' outside curb stop to a point 3 ft.

Stock: 3ft. 3/4" copper tubing 1 - 3/4" curb stop 1-Caldwell Stop box 1 - 3/4 x 5/8 lead to cop adapt. xxs. 1 - 3/4 x 3/4 cop to cop cplg. comp. =====

5/31/01 17 ft. punch - L. Souza Note: Street is cobblestone

5/14/01 Shut off at curb stop. Leak in cellar.

✓ 6-12-01 Joe Augusto Cont. to renew service from property line to inside cellar.

See next card.

DATE

BEF.

AFT.

REMARKS

12/11/78

Reamed

Sewer or drain (about 12"0) is 3 ft. E of copper main, only 2 ft. deep. We had sewer exposed but it did not break or no damage was done.

METER HISTORY

CHARGE OUTS

[illegible]

APPLICATION No.: 9282

TAP CLEARED

LOCATION: 4 Clinton Place

DATE

BEF.

AFT.

REMARKS

OWNER:

31-313

MEASURES: 3/4" Lead

8/11/10 8:00
8/11/102010-3208282
tap reamed

8/2/10 - Owner charged \$45 for water service turned on
City to renew water service from main to property line
(P. Reynolds)

8/11/10 - City crew renewed water service from main to
curb stop
15 ft - 3/4" copper tubing; 1 - 3/4" curb stop; 1
Caldwell stop box; 1 - 3/4" x 3/4" Fig. 413. Tap reamed
Foreman: Frank Bento

METER HISTORY

[illegible]

CHARGE OUTS