

LOCATION: 61 County St

APPLICATION No.: 9347

TAP CLEARED

OWNER:

31-313

MEASURES:

Dec 7, 1897

W from County St 28.6'

S from N line Nelson St 9.7'

E from W line house 17.7'

1" COPPER SERVICE

8-6-2020: Lead service line replacement program
phase 1

Contractor: P. Gioioso & Sons, TYPE CU, Diameter 1 inch

Water Pressure 100

Distance from main to curb stop 29.5'

Distance curb stop to meter 12'

Distance from curb face to curb stop 2.9'

Depth of service 3.5'

Total length of new pipe installed 41.5'

Curb stop replaced: Yes size 1"

Corporation replaced: YES Size 1"

Ball valve replaced: YES Size 1"

Remarks: 1" Union installed where shown

DATE

BEF.

AFT.

REMARKS

1-19-09 Tap reame

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

CHARGE OUTS

