

APPLICATION No.: 9404

TAP CLEARED 8903-126✓8

LOCATION: 357 Reed

OWNER: Emile Berube

MEASURES:  $3/4''$

N from	Elm	61.8 ft.
E from W line	Reed	6.2 ft.
N from S line	House	4.2 ft.

Sept. 2, 1975 Renewed from 6" outside curb stop to 6 ft. inside.

7 ft. - 3/4" Copper tubing  
2 wipe joints

3/4" Curb stop  
Buffalo Stop Box

— — —

1/19/89: Renewed from main to prop line. Stock: 18ft. 3/4" copper tubing 1- 3/4 curb stop 1-Caldwell stop box 1 - 3/4 x 5/8 lead to cop adapt. xs 1-3/4 /x3/4 Fig.413

6-10-98 Renewed from property line to ins. cellar.(12ft.ins.prop.  
line) Stock: 12' - 3/4" Copper tubing, 1 - 3/4" x 3/4" cop to cop cplg., comp.

6/13/98	Blocked sewer - dug sidewalk to check sewer line - Sewer line was ok - not broken while install line copper line on 6/10/98 - Clean out cover was missing on sewer line inside cellar.			
	Unblocked clean out & blow out sewer line - OK now. Installed 4" Clean out cover.			
	Sidewalk cut will be the same as renewal on 6/10/98.	Bento		

9/23/08 west end water main rehab contract #4 perrina constr  
renewed service from main to a pooint 4.5ft stock 4.5ft 1 copper  
tubing 1-1 corp tap 1-1x3/4 reducer ins T Ives cdm



[illegible]

## CHARGE OUTS

[illegible]