

APPLICATION No.: 9422

TAP CLEARED

LOCATION: 860 Rockdale Ave.

OWNER: Albert Crook

MEASURES: $3/4$ "

01/01/1898

N from

Hillman

69.3 ft.

W from E line

Rockdale Ave.

7.0 ft.

N from S line

Rockdale Ave.
Body of House

3.9 ft.

May 7, 1976 Renewed from 6" outside curb stop to the property line.

6 ft. - 3/4" Copper tubing 3/4" Curb Stop

Caldwell Stop Box

2 - 5/8" x 3/4" lead to copper adaptor XXS

12/16/02 This service does not line up with meter in cellar.

New measures for curb stop:

S x N line house 18.0 ft.

W x W line house	17.0 ft.
------------------	----------

W x E line body of house 9.0 ft.

W x E line Rockdale Ave. 6.2 ft.

12/07/07 - Renewed service from main to a point 2 ft East

2 ft - 3/4" copper tubing; 1 - 3/4" lead to cop adapt.

xs; Tap reamed. Foreman: D. Perry

7/23/08 - West End Water Main Rehab Contract #4 - Perrina Const.

Renewed service from main to property line

52.5 ft - 1" copper tubing; 1 - 1" corp tap; 1 - 1" curb stop;

1 - 1" x 3/4" reducer. Inspected by Tim Ives, CDM

[illegible]

CHARGE OUTS

[illegible]