

TAP CLEARED 8522 1888

OWNER: Walter M. G. Mullin, Et Ux

MEASURES:	5/8"	L lead	July 7, 1898
	E from	Brigham St.	24.2 ft.
	N from S line	Allen St.	7.0 ft.
	E from W line	house	3.0 ft.

September 16, 1975 Renewed from 6" outside curb stop to inside cellar.

14 ft. of 3/4" copper tubing (7 ft. inside) 1 wipe joint  
1 3/4" curb stop 1 Acushnet Stop Box (used)

5/30/85: Checked stop for leak. This stop has waste hole.  
No leak: sidewalk cut 6 x 3 cement Stock: 1 Caldwell stop box

3/30/90: CHAP 90 PROJ. Renewed from main to curb stop  
8 ft. 3/4" copper tubing 1-3/4" curb stop  
1-Caldwell stop box 1-3/4x5/8 Fig.413

curb stops leaks

## METER HISTORY

## CHARGE OUTS

[illegible]