

APPLICATION No.: 9457 5/8"

TAP CLEARED

LOCATION: 115 Chancery St.

OWNER: Edward S. Ramsdell

MEASURES: 5/8"

S from	Court
E from w line	Chancery
S from N line	House

93.3 ft.

7.3 ft.

5.0 ft.

DATE \_\_\_\_\_

BEF.

AFT.

7/20

REMARKS

7/20/88: TAP REAMED

5-3-99 Tap reamed

4-30-99 Tan Resmed

1/2/79: Renewed 6" outside curbstop to prop. line. 7½ ft. -

3/4" copper; 3/4" curb stop; 2-5/8" x 3/4" lead-cop. adapt.

XS; Caldwell stop box;

7/20/88 Renewed from main to curb stop. Stock: 10 ft.

3/4" copper tubing 1-3/4x5/8 Fig.413  
+++++

5-3-99 M. Pavao Const. renewed from main to property line. Stock by Contractor: 15 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop, 1 - Caldwell Stop Box, 1 - 5/8"x3/4" lead to cop. adapt. XXS, 1 - 5/8"x3/4" Fig. 413. M. Pavao Const. to maintain cut.

3/23/00 Checked punch for renewal 10 ft. - Owner inquiring about changing lead inside property before sidewalks are done in area. No leak. He is going to have lead sample taken and get back to us if still wants renewal.

lead to cop. aspt. XMS, 1 - 5/8"x3/4" Fig. 413.



