

35

APPLICATION No.: 9465

TAP CLEARED 8823-4143

LOCATION: 9 Stone

OWNER: ~~Gilbert Gonsalves~~

MEASURES:

5/8"

S from

Allen

158.7 ft.

E from W line

Stone

9.0 ft.

S from N line

House

4.3 ft.

 September 8, 1965 Renewed service from $\frac{1}{2}$ ft. outside curb stop to
 7 ft. inside curb stop.

$7\frac{1}{2}$ ft. of $\frac{3}{4}$ " copper tubing

1 $\frac{3}{4}$ " cop. to cop. stop

1 Caldwell stop box

2 lbs wiping solder

Mr Parao 994-3777

Leak in property check by Decants 3/16/88

10ft punch will call back for renewal

6/9/88: REnewed from prop line to ins. cellar (8 ft. ins.prop line)
 Stock:

8 ft. $\frac{3}{4}$ " copper tubing 1- $\frac{3}{4}$ x $\frac{3}{4}$ cop to cop cplg. comp at prop
 line. =====

Dec. 4, 1989 renewed from main to a point 3 ft.

3 ft. - $\frac{3}{4}$ " copper tubing 1 - $\frac{5}{8}$ " x $\frac{3}{4}$ " fig. 413

1 - $\frac{5}{8}$ " x $\frac{3}{4}$ " lead to cop adapt XS

DATE

BEF.

AFT.

12/4 REMARKS

MAB 32546

12/4/89

reamed

[illegible]