

1213 Purchase St

APPLICATION No.: 9583

TAP CLEARED



LOCATION: Purchase Cor. Maxfield

OWNER:

MEASURES:

6" FIRE SUPPLY - FIRE SPRINKLER

N from	Maxfield	139.3 ft.	139.3
E from W line	Purchase	11.4 ft.	12.4
S from N line	Bldg.	32.8 ft.	

Jan. 1975. Renewed from the new 12" main in Purchase St. to a point
E x W line Purchase St. 10.0 ft.

12" x 12" x 6" C.I.C.L. Class 250, tee, MJ

6" Smith gate valve, MJ

1 reg. C.I. gate box complete

5.6 ft. of 6" C.I.C.L. class 2 ductile pipe

2 6" C.I.C.L. 1/8 bend, MJ

12" x 12" x 6" teeWest 1/8 bend

N x N line Maxfield St. 139.3 ft.

N x N line Maxfield St. 139.3

E x W line Purchase St. 18.0

E x W line Purchase St. 10.0

East 1/8 bend1/8 bends to bring new piping
to old piping grade.

N x N line Maxfield St. 139.3

E x W line Purchase St. 11.0

NOTE: Fire supplies are inter-connected inside bldg. - when
shutting this service off - may have to shut off Ser. #19126 6" FS
off Maxfield St.

[illegible]

CHARGE OUTS

[illegible]