

APPLICATION No.: 9595

TAP CLEARED

LOCATION: 215 Mt. Pleasant

OWNER: Edward A. Frazee

MEASURES:

1"

N from

E from W line

W from N line

Coggeshall

Mt. Pleasant

House

99
103.2 ft.?

7.2 ft.3.0

6.7 ft.

1956 Contractor installed 8" main on east side.
Relocated service from 30" main and tapped into 8".
Copper from west side of 30" main to 8" main.

- - -

8/8/78: Renewed 6" outside of curb stop to property
line. 8 ft. - 1" copper; 1" curb stop; 2-1 1/4" x 1" lead to
cop. adapt. XXS; Caldwell stop box;

AUG 19 1981 - Renewed service from the 8" main to the prop.
line. 21 ft. - 1" copper; 1" x 1" Fig. 413; 1" curb stop;
Caldwell stop box; Note: No saddle on transite pipe.
Reused lead to copper adapt.

- - -

DATE

BEF.

AFT.

REMARKS

AUG 19 1981

Reamed

V

[illegible]

CHARGE OUTS

[illegible]