

APPLICATION No.: 9651

TAP CLEARED 8610-1316 ✓

LOCATION: 171 Division

OWNER: Picarding Barros

MEASURES:

 $\frac{1}{2}$ "

LEAD

| | | |
|---------------|----------|-------|
| E from | Crapo | 381.0 |
| S from N line | Division | 7.0 |
| W from E line | Bldg. | 0.2 |

July 10, 1957 Renewed from a point $\frac{1}{2}$ ft. outside curb stop to a point 2 ft. inside curb stop $2\frac{1}{2}$ ft. of $\frac{3}{4}$ " copper tubing
 1 lb. wiping solder $\frac{3}{4}$ " copper stop (used)
 2- $\frac{3}{4}$ " cop. to I. cplg., A-1551

Feb. 24, 1953 Renewed from meter box to inside cellar
 9 ft. of $\frac{3}{4}$ " copper tubing

Aug. 15/78 Locating leak on Division St. we picked up the meter pit cover and it fell into the meter pit breaking the $\frac{5}{8}$ " meter & both meter tailpieces. We had to use different fittings to make repairs without digging it up. Hansen J. Rodrigues

3/5/86: Renewed from curb stop to 6.0ft. outside curb stop
 Stock: 6.0ft. $\frac{3}{4}$ " copper tubing 2- $\frac{3}{4}$ " curb stop
 1- Caldwell stop box 1 - $\frac{3}{4}$ x $\frac{5}{8}$ lead to cop adapt.xs.

(NOTE) cut in $\frac{3}{4}$ C stop 5.5
 outside c. stop between 2 gas
 mains also new $\frac{3}{4}$ C stop on
 sidewalk. Ser. has copper from
 6.0 O.S.C.S. to meter pit

Over for more work on service

[illegible]

CHARGE OUTS

| | | |
|----------------------------------|---|----------------------------|
| 4/18/06 | Renewed from main to a point 15 ft. N x main. | Stock: 15 ft. 3/4" copper; |
| 3/4" x 3/4" cop-cop cplg., comp; | 5/8" x 3/4" Fig. 413 | Tap reamed Foreman: Bento |