

APPLICATION No.: 9672

TAP CLEARED ✓

LOCATION: 30 Willard

OWNER: Robert Bancroft

MEASURES: $\frac{1}{2}$ "

W from	Brock Ave.	277.0 ft.
N from S	Willard	8.9 ft.
E from W	house	9.0 ft.

Oct. 17, 1974 Renewed from the main to a point 1 ft.
from the main. Leak at tap.

1 ft. - $\frac{3}{4}$ " Copper tubing 1 wipe joint
 $\frac{3}{4}$ " x $\frac{3}{4}$ " Fig. 413

- - -

12-22-98 Renewed from main to property line. Stock:
18 ft. - $\frac{3}{4}$ " Copper tubing, 1 - $\frac{3}{4}$ " Curb Stop,
1 - Caldwell Stop Box, 1 - $\frac{5}{8}$ " x $\frac{3}{4}$ " lead to cop.
adapt. XXS, 1 - $\frac{5}{8}$ " x $\frac{3}{4}$ " Fig. 413.

7/26/01 Renewed from property line to inside cellar (10
ft. ins. prop. line). Stock: 10 ft. - $\frac{3}{4}$ " copper tubing,
1 - $\frac{3}{4}$ " x $\frac{3}{4}$ " cop to cop cplg., comp.

DATE

BEF.

AFT.

REMARKS

10/17/74

Reamed

OK. EACCTA.

12-22-98

1998201382

12-22-98

Tap reamed

[illegible]