

APPLICATION No.: 9730

TAP CLEARED

LOCATION: 601 William Cor. Pleasant

DATE

BEF.

AFT.

REMARKS

OWNER: Public Library

MEASURES: 2"

W from

N from S line

W from E line

Copper

Pleasant

William

Bldg.

71.3 ft.

6.0 ft.

28.9 ft.

May 14, 1973 Renewed from the main to curb stop.

This service has 2 - 1" taps & 1 3/4" tap.

The 3/4" tap is on the reverse side of main.

The 2" gate was removed and returned to shop and the gate box and lead also returned.

1 ft. - 2" Copper tubing 2" hays curb stop

R-144 Stop Box 2 - 1" x 1 1/4" Fig. 413

1" x 3/4" Fig. 413 11 ft. - 3/4" Copper

16 ft. - 1" Copper 1" x 1" x 2" Cop. Tee

1" Tee 1" Elbow

3/4" Elbow

- - -

October 8, 1971 Rewiped the three joints that feed a 2" service into library.

METER HISTORY

[illegible]

CHARGE OUTS