

SERVICE

Application No.

9732

St. & No. 5-7 Riverside Ave., N.S.

Size Pipe

Kind Pipe

Laid

5-8" 3/4" ~~11-lead~~ Copper May 23, 1900N from Coffin Ave. St. 121.0 ft.E from W line Riverside Ave. St. 9.5 ft.N from S line house St. 2.8 ft.

INACTIVE April 1979

City

19 ft. Earth

Taker

5 ft. Earth1 1518 ft. Pipe6 1/2 ft. Pipe1 372 004 52

7-21-44 New from 2' inside of stop to line
10' - 5/8" H.lead pipe

8-22-50, ser. leak, new from curb stop to
middle of sidewalk using 4 ft. 3/4" cop. tub.

10-17-50, new from a point 4 ft. from curb stop
in sidewalk to inside cellar using 14 1/2 ft. of
3/4" copper. This service is now new from curb-
stop to inside cellar. Bill No. 46666 for
8 1/2 ft. of pipe.

4/79 discontinued, plugged at main while cement
lining. ~~Material abandoned in ground~~