

APPLICATION No.: 9792

TAP CLEARED ✓

LOCATION: 85-9 & R. Purchase St.

OWNER: Joseph P. Curry

DATE

BEF.

AFT.

REMARKS

9-3-71

Reamed

91411504

MEASURES:

5/8"

H lead

Au.g 29,1900

N from

Rivet St.

148.3 ft.

E from W line

Purchase St.

6.9 ft.

N from S line

house

22.0 ft.

 September 3, 1971 Renewed from the main to a point 4 ft. from the main.

4 ft. 3/4" copper tubing

1 3/4" x 3/4" Hays fig. 413

2 wiped joints

 September 25, 1972 Renewed from the main to the property line.

14 ft. 3/4" copper tubing

1 3/4" Hays curb stop

1 lb. wiping solder

1 Caldwell Stop Box

 10/8/91: Renewed from prop line to ins.cellar
 Stock: 10ft. 3/4" copper tubing same curb stop
 1-Caldwell stop box 1-3/4x3/4 cop-cop cplg.comp.
 =====

7/14/2010 W.C. Smith + Sons Killed water service at curb stop.
 Bldg. demolished due to Fire. Inspected by Percy

[illegible]

APPLICATION No.: 17114C

LOCATION: R 85-89 Purchase

OWNER:

MEASURES: $5/8''$

Connection of 5/8" ser. 9792

TAP CLEARED

[illegible]

[illegible]

CHARGE OUTS

[illegible]