

APPLICATION No.: 9819 3/4th

TAP CLEARED

LOCATION: 60 Chestnut St.

OWNER: Mrs. A. L. Pitman

MEASURES: $3/4''$

S from Maxfield 61.8 ft.

W from E line Chestnut 6.9 ft.

N from N line House 0.6 ft.

June 28, 1977: Renewed from 6" outside curb stop to 2 ft. inside curb stop. 2 $\frac{1}{2}$ ft.-3/4" copper; 3/4" curb stop; 2-5/8" x 3/4" lead to copper Adapt. XXS; Caldwell stop box; (This service has a telephone & electric duct over it. Impossible to repair any more of it inside of curbstop unless it is relocated)

12/12/03 Renewed from main to a point 20 ft. Stock: 20 ft. 3/4" copper tubing; 5/8" x 3/4" lead-cop adapt. XXS; 3/4" x 3/4" Fig 413 Tap reamed

NOTE: If there is a leak in the sidewalk in the future, service will have to be re-located 5 x existing service. Grenon

10/6/04 Silva Construction renewed from main to curb stop.
Stock: 19.5 ft. - 3/4" Copper Tubing
3/4" Curb Stop
Caldwell Stop Box
3/4" Corporation Tap

8/28/17: Service renewed from curb stop to meter. Contractor WC SMITH
Inspector P.Reynolds

DATE _____

BEF.

AFT.

REMARKS

12/12/03

8:30

2003-500-3947

NStar	Gas & Elec	Ver	ComCast
-------	------------	-----	---------

12/12/03

Tap reamed

METER HISTORY

CHARGE OUTS

[illegible]