

APPLICATION No.: ~~9833~~

9833

TAP CLEARED

LOCATION: 25 KeeneOWNER: Jos. TrippMEASURES: 5/8"

W from

Park

156.2 ft.

S from N line

Keene

9.5 ft.

E from W line

house

2.4 ft.

April 4, 1974 Renewed from $\frac{1}{2}$ ft. outside curb stop to property line.

7 ft. - $\frac{3}{4}$ " Copper tubing 2 wipe joints
 $\frac{3}{4}$ " Curb Stop Stop Box

8/7/78: Renewed from main to 3 ft. front of main.

3 ft. - $\frac{3}{4}$ " copper; $\frac{5}{8}$ " x $\frac{3}{4}$ " Fig. 413; $\frac{5}{8}$ " x $\frac{3}{4}$ "
lead to cop. adapt. XS;

Leak inside building 2/27/89 Smalley

Jan. 22, 1998 Leak under the floor on the outlet end of the meter.

Owner notified to call plumber. Meter reader noticed leak detector moving & notified owner. G. Pitta

11/12/04 Silva Construction renewed from main to a point 25 ft.

Stock: 25 ft. - $\frac{3}{4}$ " Copper tubing

$\frac{3}{4}$ " Curb stop

Caldwell stop box

$\frac{3}{4}$ " Corporation Tap

NOTE: TURN OVER FOR MORE REPAIR/INFO ON SERVICE

DATE

BEF.

AFT.

REMARKS



8/7/78

Reamed

7/9/05 8:30 AM 2005-301-1401

[illegible]

CHARGE OUTS

[illegible]