

APPLICATION No.: ~~953~~ 9853

TAP CLEARED

LOCATION: 41 MitchellOWNER: Mary De Mello

1/1/1900

MEASURES: 5/8"

S from

E from W line

N from S line

Sawyer

Mitchell

House

~~221.2 ft.~~~~7.3 ft.~~~~4.2 ft.~~

Jan. 7, 1975 Renewed from 6" outside curb stop to property line.

8 ft. - 3/4" Copper tubing 3/4" Curb Stop
 2 - 5/8" x 3/4" lead to cop. Caldwell Stop Box
 adaptor XXS

- - -

Dec 26, 1995: Renewed from main to a point 2ft

Stock: 2ft 3/4" copper tubing 1-3/4x5/8 lead-cop dapt. xxs

1- 3/4 x 5/8 Fig 413

=====

Aug 26, 1997: Renewed from main to ins. cellar (10ft ins. prop line)

Stock: 24ft 3/4" copper tubing 1-3/4" curb stop

1-caldwell stop box 1-3/4x5/8 Fig 413

=====

4/6/09 - City crew renewed service from main to property line

13 ft - 3/4" copper tubing; 1 - 3/4" curb stop; 1 Caldwell stop box; 1 - 5/8" x 3/4" Fig. 413; Tap reamed. Foreman: Dennis Monty

DATE

BEF.

AFT.

REMARKS

12/26/95

9552-00180

Clear Elect

8/26/97

12/26/95: tap reamed 97 3502201

8/26/97: tap reamed

4-6-09

Tap reamed

NEW MEASURES 5-19-2009

SXSL SAWYER ST. - 221.2'

EXWL MITCHELL ST. - 2.4'

SXSL HOUSE - 3.3'

SXNL HOUSE - 30.7'

[illegible]

CHARGE OUTS

[illegible]