

360

APPLICATION No.: 9862 4"

TAP CLEARED

LOCATION: 562 Coggeshall St.

OWNER: Motor School

MEASURES:

4"

FIRE SUPPLY

Jan 26, 1901

E from

Ashley Blvd. (S)

124.0 ft.

N from S line

Coggeshall

11.3 ft.

E from W line

Bldg.

23.5 ft.

July 1983 Blocked tap during cement lining - Cleared  
 by removing the bonnet off the 4" gate & repl.  
 with 6 - 2½" x 5/8" bolts & nuts  
 1 - #10 Caldwell gate box, complete  
 -----

DATE

BEF.

AFT.

REMARKS

6/26/83

on



[illegible]

## CHARGE OUTS

[illegible]