

APPLICATION No.: 9880

## TAP CLEARED

LOCATION: 190 Merrimac

OWNER: Margaret Crowley

MEASURES:  $3/4"$

E from

Cottage

101.7ft.

N from S line

Merrimac

9.2 ft.

W from E line

House

2.0 ft.

Aug. 6, 1953 Renewed 1 ft. from tap.

1 ft. - 3/4" Copper tubing 1" cop to 3/4" cplg. 413  
1 wipe joint - - -

June 24, 1974 Renewed from 6" outside curb stop to property line.

8 ft. - 3/4" Copper tubing

3/4" curb stop

1 wipe joint

Caldwell Stop Box

5/8" x 3/4" Cop. to lead adaptor

July 2, 1974 Renewed from the property line to inside cellar.

16 ft. - 3/4" Copper tubing 3/4" x 3/4" cop to cop  
cplg.

6-8-01Renewed from main to curb stop. Stock:

10ft.- 3/4" Copper tubing, 1-3/4" Curb Stop,

1-3/4"x3/4" Fig. 413.

12/7/06 Caliacco Corp. replaced corporation fitting and reconnected to main. Used 4' of 3/4" copper tubing. Owner reported low pressure prior to the work.

[illegible]



[illegible]

## CHARGE OUTS

[illegible]