

APPLICATION No.: 9939

## TAP CLEARED

LOCATION: 62 Jenny Lind

OWNER: Mary E Saed

MEASURES: 3/4"

N from

North

67.9 ft.

W from E line

Jenny Lind

7.2 ft.

N from S line

House

11.0 ft.

Jan. 5, 1976 Renewed from 1 ft. outside curb stop to property line.

✓ 8 ft. - 3/4" Copper tubing 3/4" Curb Stop

Caldwell Stop Box

2 - 5/8" x 3/4" lead to cop adapt XS

- - -

✓ June 21, 1976 Renewed from the main to the curb stop.  
22 ft. - 3/4" Copper tubing 1" x 3/4" Fig. 413

Oct. 31, 1993 shut off for repairs at curb stop.

Aug. 9, 1994 Pitta turn on - found leaking ins. property line. left in off position

Note: After Oct. 31, 1994 - must change service to copper before turning on

✓ 10/20/94: Renewed from prop line to ins. cellar

9 ft ins. prop line Stock: 9ft 3/4" copper tubing

same Caldwell stop box 1-3/4x3/4 cop-cop cplg.comp.

=====

6/12/08 - West End Water Main Rehab Contract # 4 - Perrina Const.

Renewed water service from main to a point 6 ft

6 ft - 1" copper tubing; 1 - 1" corp tap; 1 - 1" x 3/4" reducer

Inspected by Tim Ives, CDM

-----

DATE

BEF.

AFT.

REMARKS

6/21/76

Reamed

1-20-94

9442-05398

clean Elec.

7-30-07

B/W

Brow

9:15

2007-300-5449

clear of Elec.



[illegible]

## CHARGE OUTS

[illegible]