

APPLICATION No.: 9949

## TAP CLEARED

LOCATION: 74 Jenny Lind S.E. Cor. Hillman

OWNER: Louisa E Fisher

DATE BEF. AFT. REMARKS

10-19-99 Tap reamed

## MEASURES:

 $\frac{3}{4}$ "

N from

Kempton

422.7 ft.

W from E line-

Jenny Lind

7.2 ft.

S from N line

House

3.5 ft.

1/11/78: Renewed 6" outside curb stop to prop. line.  $7\frac{1}{2}$  ft.✓ 3/4" copper; 3/4" curb stop; 2-5/8" x 3/4" lead to cop.  
adapt. XXS; Caldwell stop box;

10-19-99 DW White renewed from main to curb stop.

Stock: 21 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop

✓ 1 - Caldwell Stop Box (same), 1 - 5/8" x 3/4" Fig. 413.

DW White to maintain cut.

~~6/12/08 - West End Water Main Rehab Contract # 4 - Perrina Const.~~7/12/06 RJ Canessa renewed service from property line to  
meter in cellar. See new measures below

S x S line Hillman St. 7.0 ft.

W x E line Jenny Lind St. 7.0 ft.

S x N line house 3.0 ft.

W x W line house 15.5 ft.

Cplg. W x property line 1.6 ft.

over



[illegible]

## CHARGE OUTS

[illegible]

9949

LOCATION: 74 Jenny Lind St S.E. corner Hillman St

OWNER:

31-313

MEASURES: 3/4" Copper

6/12/08 - West End Water Main Rehab Contract # 4 - Perrina Const.  
Renewed water service from main to a point 7 ft  
7 ft - 1" copper tubing; 1 - 1" corp tap; 1 - 1" x 3/4" reducer  
Inspected by Tim Ives, CDM

-----

# TAP CLEARED

DATE \_\_\_\_\_

BEF.

AFT

REMARKS



[illegible]

112