

APPLICATION No.: 9984

TAP CLEARED

LOCATION: 15 Scott St

OWNER:

31-313

MEASURES:

Sept. 5, 1901

W X County St

153.5 ft

S X N Line Scott St

9.0 ft

W X E Line House

7.6 ft

1" Copper Service

07/08/2019 Lead Service Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 100

Distance main to curb stop (ft) 23

Distance curb stop to meter (ft) 23

Distance from curb face to curb stop (ft) 1

Depth of service (Ft) 4

Total length of new pipe installed (ft) 46

Curb stop replaced: yes size 1"

Corporation replaced: yes size 1"

Ball valve replaced: yes size 1"

DATE

BEF.

AFT.

REMARKS

7/27/56 Ream

[illegible]